

**FORMAT-B (Annexure- V)**

**LUMPSUM ITEMS: Tentative schedule of works, please refer the note attached herewith.**

<b>Sl. No.</b>	<b>Item of Supply</b>	<b>Unit</b>	<b>Qty</b>	<b>Rate ( In figure)</b>	<b>Rate in Words</b>	<b>Nos. of Month</b>	<b>Amount (Rs.)</b>
1.	Running and maintenance of Air conditioning system consisting of 14 nos. of window/ split AC.	Lumpsum per month	14			12	
2.	Running and maintenance of Fire Fighting system consisting of 20 nos. of fire bottles of different capacities.	Lumpsum per month	20			12	
3.	Running and maintenance of 1 no. of DG Set. Make: Kirloskar, 30 KV, Air Cooled Engine.	Lumpsum per month	1			12	
4.	Running and maintenance of 1 no. of Pumping system consisting of 1 no. 4 HP, submersible pump.	Lumpsum per month	1			12	
<b>Total</b>							

Rupees.....

## NOTE

### Tentative Schedule of work for serial number 1 above.

- General servicing: This includes cleaning checking the serviceability etc. in situ, quantity 14 nos.
- Gas Refilling: If required, quantity 6 nos.
- Spare parts: Such as Air filter, Relay (start/ Run), capacitor, Thermostat etc. if required, quantity 5 nos.

### Tentative Schedule of work for serial number 2 above.

- General servicing: This includes cleaning, checking the serviceability etc. in situ, quantity 20 nos.
- Refilling: Refilling as and when due (once only) , as well as if required in between
  - ▶ DCP type 5 kg capacity quantity 6 nos.
  - ▶ CO<sub>2</sub> type 4.5 kg capacity quantity 4 nos.
  - ▶ ABC type quantity 6 nos.
  - ▶ CO<sub>2</sub> type 2 kg capacity quantity 4 Nos.

### Tentative Schedule of work for serial number 3 above.

- The maintenance consist of 1 number DG Set, Make Kirloskar 30 KV, Air cooled engine.
- Replacing of engine oil, make kirloskar of correct grade qnty. 10 to 12 ltrs as required (once only).
- Replacing suitable diesel filter 2 nos. and Mobil filter 1 no. along with engine oil change.
- General servicing and checking the functioning of the Machine parameters etc. by authorized agency.
- Control panel, change over switch, battery maintenance (Pouring Distilled Water, terminal lug, including smearing white petroleum jelly on the terminal etc. as required).

### Tentative Schedule of work for serial number 4 above.

- The maintenance consist of 1 number of 4 HP, Submersible Pump.
- Repair and replacement of Voltmeter, Ameter etc. of correct rating, timer, starter, HRC fuse, TPN isolator etc. as required, quantity 4 nos. ( If required)